

# LOT 1, PRW

FORM NO. GWS-31 10/94	<b>WELL CONSTRUCTION AND TEST REPORT</b> STATE OF COLORADO, OFFICE OF THE STATE ENGINEER	For Office Use only
-----------------------------	---	---------------------

1.	<b>WELL PERMIT NUMBER</b> <u>233096</u>
2.	<b>OWNER NAME(S)</b> <u>Jeffrey S. Auxier</u> Mailing Address <u>P O Box 2891</u> City, St. Zip <u>Edwards, CO 81632</u> Phone ( ) _____

3.	<b>WELL LOCATION AS DRILLED:</b> <u>NE 1/4 SW 1/4, Sec. 13 Twp. 49 N Range 8 E</u> DISTANCES FROM SEC. LINES: <u>1900</u> ft. from <u>S</u> Sec. line. and <u>2250</u> ft. from <u>W</u> Sec. line OR <small>(north or south) (east or west)</small> SUBDIVISION: <u>King Gulch</u> LOT <u>2</u> BLOCK _____ FILING(UNIT) _____ STREET ADDRESS AT WELL LOCATION: _____
----	---

4.	<b>GROUND SURFACE ELEVATION</b> <u>7600</u> ft. <b>DRILLING METHOD</b> <u>Air Percussion</u> <b>DATE COMPLETED</b> <u>June 6, 2001</u> <b>TOTAL DEPTH</b> <u>320</u> ft. <b>DEPTH COMPLETED</b> <u>320</u> ft.
----	---

<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th style="width: 15%;">Depth</th> <th>Description of Material (Type, Size, Color, Water Location)</th> </tr> <tr> <td>0-34</td> <td>Brown Sandy Clay &amp; Boulders</td> </tr> <tr> <td>34-283</td> <td>Brown Clay</td> </tr> <tr> <td>283-290</td> <td>Gray Sand &amp; Gravel <span style="float: right;">283</span></td> </tr> <tr> <td>290-320</td> <td>Gray Clay</td> </tr> </table>	Depth	Description of Material (Type, Size, Color, Water Location)	0-34	Brown Sandy Clay & Boulders	34-283	Brown Clay	283-290	Gray Sand & Gravel <span style="float: right;">283</span>	290-320	Gray Clay	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="3">6. HOLE DIAM. (in.)</th> </tr> <tr> <th>From (ft)</th> <th>To (ft)</th> <th></th> </tr> <tr> <td><u>8-3/4</u></td> <td><u>0</u></td> <td><u>40</u></td> </tr> <tr> <td><u>6</u></td> <td><u>40</u></td> <td><u>320</u></td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5">7. PLAIN CASING</th> </tr> <tr> <th>OD (in)</th> <th>Kind</th> <th>Wall Size</th> <th>From(ft)</th> <th>To(ft)</th> </tr> <tr> <td><u>6-5/8</u></td> <td><u>Steel</u></td> <td><u>188</u></td> <td><u>+1</u></td> <td><u>39</u></td> </tr> <tr> <td><u>4</u></td> <td><u>Plastic</u></td> <td><u>250</u></td> <td><u>20</u></td> <td><u>260</u></td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5">PERF. CASING: Screen Slot Size: <u>1/8</u></th> </tr> <tr> <th>OD (in)</th> <th>Kind</th> <th>Wall Size</th> <th>From(ft)</th> <th>To(ft)</th> </tr> <tr> <td><u>4</u></td> <td><u>Plastic</u></td> <td><u>250</u></td> <td><u>260</u></td> <td><u>320</u></td> </tr> </table>	6. HOLE DIAM. (in.)			From (ft)	To (ft)		<u>8-3/4</u>	<u>0</u>	<u>40</u>	<u>6</u>	<u>40</u>	<u>320</u>	7. PLAIN CASING					OD (in)	Kind	Wall Size	From(ft)	To(ft)	<u>6-5/8</u>	<u>Steel</u>	<u>188</u>	<u>+1</u>	<u>39</u>	<u>4</u>	<u>Plastic</u>	<u>250</u>	<u>20</u>	<u>260</u>	PERF. CASING: Screen Slot Size: <u>1/8</u>					OD (in)	Kind	Wall Size	From(ft)	To(ft)	<u>4</u>	<u>Plastic</u>	<u>250</u>	<u>260</u>	<u>320</u>
Depth	Description of Material (Type, Size, Color, Water Location)																																																									
0-34	Brown Sandy Clay & Boulders																																																									
34-283	Brown Clay																																																									
283-290	Gray Sand & Gravel <span style="float: right;">283</span>																																																									
290-320	Gray Clay																																																									
6. HOLE DIAM. (in.)																																																										
From (ft)	To (ft)																																																									
<u>8-3/4</u>	<u>0</u>	<u>40</u>																																																								
<u>6</u>	<u>40</u>	<u>320</u>																																																								
7. PLAIN CASING																																																										
OD (in)	Kind	Wall Size	From(ft)	To(ft)																																																						
<u>6-5/8</u>	<u>Steel</u>	<u>188</u>	<u>+1</u>	<u>39</u>																																																						
<u>4</u>	<u>Plastic</u>	<u>250</u>	<u>20</u>	<u>260</u>																																																						
PERF. CASING: Screen Slot Size: <u>1/8</u>																																																										
OD (in)	Kind	Wall Size	From(ft)	To(ft)																																																						
<u>4</u>	<u>Plastic</u>	<u>250</u>	<u>260</u>	<u>320</u>																																																						
REMARKS:	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="2">8. FILTER PACK:</th> <th colspan="2">9. PACKER PLACEMENT</th> </tr> <tr> <td>Material</td> <td>_____</td> <td>Type</td> <td>_____</td> </tr> <tr> <td>Size</td> <td>_____</td> <td>Depth</td> <td>_____</td> </tr> <tr> <td>Interval</td> <td>_____</td> <td></td> <td></td> </tr> </table> <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <th colspan="5">10. GROUTING RECORD:</th> </tr> <tr> <th>Material</th> <th>Amount</th> <th>Density</th> <th>Interval</th> <th>Placement</th> </tr> <tr> <td>Cement</td> <td><u>40gal</u></td> <td><u>8bags</u></td> <td><u>5-39</u></td> <td><u>poured &amp; vibrated</u></td> </tr> </table>	8. FILTER PACK:		9. PACKER PLACEMENT		Material	_____	Type	_____	Size	_____	Depth	_____	Interval	_____			10. GROUTING RECORD:					Material	Amount	Density	Interval	Placement	Cement	<u>40gal</u>	<u>8bags</u>	<u>5-39</u>	<u>poured &amp; vibrated</u>																										
8. FILTER PACK:		9. PACKER PLACEMENT																																																								
Material	_____	Type	_____																																																							
Size	_____	Depth	_____																																																							
Interval	_____																																																									
10. GROUTING RECORD:																																																										
Material	Amount	Density	Interval	Placement																																																						
Cement	<u>40gal</u>	<u>8bags</u>	<u>5-39</u>	<u>poured &amp; vibrated</u>																																																						

11.	<b>DISINFECTION:</b> Type <u>HTH</u> Amt Used <u>3 oz.</u>
-----	--

12.	<b>WELL TEST DATA:</b> <input type="checkbox"/> Check box if Test Data is submitted on Form No. GWS 39 Supplemental Well Test <b>TESTING METHOD</b> <u>Air Lift</u> Static Level <u>221</u> ft. Date/Time measured <u>6-6-01 2:00pm</u> Production Rate <u>20</u> gpm Pumping level <u>320</u> ft. Date/Time measured <u>6-6-01 3:00pm</u> Test length (hrs.) <u>1</u> Remarks _____
-----	--

13. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge. (Pursuant to Section 24-4-104, 105 & 106 C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.)

<b>CONTRACTOR</b> <u>American Drilling Service</u> Phone <u>(719) 942-3568</u> Lic No <u>1280</u> Mailing Address <u>9934 Hwy. 50 Howard, CO 81233</u>
---

Name/Title (Please type or print) <u>David Dewberry/President</u>	Signature 	Date <u>3-5-2</u>
--	---------------	----------------------

LOT 1 IPRW

FORM NO. GWS-32 10/94

PUMP INSTALLATION AND TEST REPORT  
STATE OF COLORADO OFFICE OF THE STATE ENGINEER

For Office Use only

1. WELL PERMIT NUMBER 223096

2. OWNER NAME(S) Jeffrey S. Axler  
 Mailing Address P.O. Box 289  
 City, St. Zip Edwards, CO 81632  
 Phone ( )

3. WELL LOCATION AS DRILLED: N 1/4 S 1/4 Sec. 13 Twp. 49 Range 5  
 DISTANCES FROM SEC. LINES:  
1900 ft. from S Sec. line and 2050 ft. from W Sec. line  
(north or south) (east or west)  
 SUBDIVISION: King Gulch LOT     BLOCK     FILING(UNIT)      
 STREET ADDRESS AT WELL LOCATION:    

4. PUMP DATA: Type Submersible Installation Completed June 11, 2001  
 Pump Manufacturer Myers Pump Model No. 257152-11  
 Design GPM 12 at RPM 3450 HP 1.5 Volts 240 Full Load Amps 15  
 Pump Intake Depth 300 Feet, Drop/Column Pipe Size 1 Inches, Kind SCR 80

ADDITIONAL INFORMATION FOR PUMPS GREATER THAN 50 GPM:  
 TURBINE DRIVER TYPE:  Electric  Engine  Other      
 Design Head     feet, Number of Stages     Shaft size     inches.

5. OTHER EQUIPMENT:  
 Airline Installed  Yes  No, Orifice Depth ft.     Monitor Tube Installed  Yes  No, Depth ft.      
 Flow Meter Mfg.     Meter Serial No.      
 Meter Readout  Gallons,  Thousand Gallons,  Acre feet,  Beginning Reading    

6. TEST DATA:  Check box if Test data is submitted on Supplemental Form.  
 Date 6-11-01 6-11-01  
 Total Well Depth 320 Time 12:00pm 2:00pm  
 Static Level 221 Rate (GPM) 12 12  
 Date Measured 6-11-01 Pumping Lvl. 221 221

7. DISINFECTION: Type HTH Amt. Used 2.4

8. Water Quality analysis available  Yes  No

9. Remarks      
     
     
   

10. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge [Pursuant to Section 24-4-104 (13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.]

CONTRACTOR American Drilling Service Phone (719) 242-3568 Lic. No. 1251  
 Mailing Address 9934 Hwy. 50 Howard, CO 81233

Name/Title (Please type or print) <u>Bradford Dewberry/President</u>	Signature <u>Bradford Dewberry</u>	Date <u>7/18/01</u>
---	---------------------------------------	------------------------